

POWER SYMBOLS

WALL MOUNTED	FLOOR BOX	POKE-THROUGH	CEILING MOUNTED	
				DUPLEX RECEPTACLE
				QUAD RECEPTACLE
				SINGLE RECEPTACLE
				ISOLATED GROUND DUPLEX RECEPTACLE
				ISOLATED GROUND QUAD RECEPTACLE
				COMBINATION IG DUPLEX RECEPTACLE, DUPLEX RECEPTACLE AND TELEPHONE/ DATA SYSTEMS OUTLET
				SPECIAL RECEPTACLE – REFER TO SPECIAL RECEPTACLE SCHEDULE
				JUNCTION BOX WITH FLEXIBLE CONDUIT AND FINAL EQUIPMENT OR FURNITURE SYSTEM POWER CONNECTION
<p> WP ADJACENT LETTERS IN THE SYMBOLS ABOVE INDICATE THE FOLLOWING: XX "CR" INDICATES CHILD RESISTANT (SAFETY TYPE) "CS" INDICATES CHARGING STATION "E" INDICATES RECEPTACLE FED BY EMERGENCY CIRCUIT "EP" INDICATES RECEPTACLE IS EXPLOSION PROOF "EWC" INDICATES RECEPTACLE SERVES ELECTRIC WATER COOLER "GFI" INDICATES RECEPTACLE HAS GROUND FAULT CIRCUIT INTERRUPTER "IG" INDICATES RECEPTACLE HAS ISOLATED GROUND-COMPUTER "TVS" INDICATES RECEPTACLE HAS TRANSIENT VOLTAGE SURGE SUPPRESSION "WP" INDICATES RECEPTACLE HAS WATERPROOF COVER "XX" INDICATES RECEPTACLE CIRCUIT NUMBER "S" INDICATES RECEPTACLE IS SAFETY TYPE </p>				
	DUPLEX RECEPTACLE – MOUNTING HEIGHT AS NOTED ABOVE COUNTER			
	CLOCK OUTLET AND CLOCK FOR INTEGRATED CLOCK SYSTEM.			
	DUAL FACED CLOCK OUTLET AND CLOCK FOR INTEGRATED CLOCK SYSTEM.			

**CHICAGO PUBLIC SCHOOLS
CAPITAL IMPROVEMENT PROGRAM
INFORMATION TECHNOLOGY SERVICES
INFRASTRUCTURE STANDARDS**

POWER SYMBOLS

	PROJECT NUMBER	SCALE NONE	DATE 08/28/08
	SHEET NO. ED.002		

NO.	DATE	REVISION	BY	DESIGNED CPS	DRAWN CPS	CHECKED CPS	APPROVED CPS			