


TRADE SIZE *	CABLE OUTSIDE DIAMETER									
	cm (in.)									
	0.33 (0.13)	0.46 (0.18)	0.56 (0.22)	0.61 (0.24)	0.74 (0.29)	0.79 (0.31)	0.94 (0.37)	1.35 (0.53)	1.58 (0.62)	178 (0.70)
1/2*	1	1	0	0	0	0	0	0	0	0
3/4*	6	5	4	3	2	2	1	0	0	0
1	8	8	7	6	3	3	2	1	0	0
1 1/4	16	14	12	10	6	4	3	1	1	1
1 1/2	20	18	16	15	7	6	4	2	1	1
2	30	26	22	20	14	12	7	4	3	2
2 1/2	45	40	36	30	17	14	12	6	3	3
3	70	60	50	40	20	20	17	7	6	6
3 1/2	-	-	-	-	-	-	22	12	7	6
4	-	-	-	-	-	-	30	14	12	7

* CPS STANDARD MIN. - 3/4"C

1. CATEGORY 5e CABLE APPROXIMATELY SIZED AT .22" O.D. CATEGORY 6 APPROXIMATELY SIZED AT 0.24/0.26" O.D. VERIFY WITH APPROVED MANUFACTURER PRODUCT.
2. CABLE TABLE 5.9 FROM 2000 BICSI TDMM, 10TH EDITION MANUAL, CH. 5 HORIZONTAL CABLING SYSTEM. INCORPORATES GUIDELINES FROM ANSI/TIA/EIA - 569-B

 CHICAGO PUBLIC SCHOOLS CAPITAL IMPROVEMENT PROGRAM INFORMATION TECHNOLOGY SERVICES INFRASTRUCTURE STANDARDS						CABLE CONDUIT FILL CHART																																					
<table border="0"> <tr> <td style="width: 20px;">NO.</td> <td style="width: 20px;">DATE</td> <td style="width: 50px;">REVISION</td> <td style="width: 20px;">BY</td> <td style="width: 10px;"></td> <td style="width: 10px;"></td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </table>					NO.	DATE	REVISION	BY																											<table border="0"> <tr> <td style="width: 40px;">PROJECT NUMBER</td> <td style="width: 40px;">SCALE</td> <td style="width: 40px;">DATE</td> </tr> <tr> <td> </td> <td>NONE</td> <td>08/28/08</td> </tr> </table>		PROJECT NUMBER	SCALE	DATE		NONE	08/28/08	SHEET NO. ED.003
NO.	DATE	REVISION	BY																																								
PROJECT NUMBER	SCALE	DATE																																									
	NONE	08/28/08																																									