

- NOTES.

 1. PROVIDE A 24"W x 24"L x12"D NEMA 4X RATED ENCLOSURE WITH LOCKING DOOR.

 2. THE ENCLOSURE'S DOOR SHALL BE MONITORED BY DOOR POSITION SWITCH CONNECTED TO THE EXISTING HONEYWELL WISTA 50P INTRUSION DETECTION SYSTEM.

 3. EACH COMPONENT SHALL BE MOUNTED WITH A MINIMUM OF 2" OF SPACE BETWEEN ADJACENT COMPONENTS OR THE ENCLOSURE WALL.

 4. REFER TO SITE PLAN AND DETAILS FOR CASEL REQUIREMENTS AND ROUTINE.

 5. PROVIDE A 6AWG GROUNDING CABLE CONNECTION FROM IT ENCLOSURE TOB BACK TO NEAREST ELECTRICAL GROUNDING SYSTEM.

CHICAGO PUBLIC SCHOOLS CAPITAL IMPROVEMENT PROGRAM OFFICE OF SAFETY AND SECURITY

SECURITY STANDARDS IT ENCLOSURE "NE-3"DETAIL

SHEET NO. PROJECT: CPS Chicago Public ITS SYSTEM-DETAILS ED-242 ROJECT NUMBER SCALE CPS Schools XXXX NONE 02/27/19 CPS