



- WHITE #12 THHN STRANDED

BLACK, RED, OR BLUE #12 THHN STRANDED

GREEN #12 THHN STRANDED WITH YELLOW TRACER

GREEN #12 THHN

## **NOTES:**

- 1. EACH RECEPTACLE SHALL BE MOUNTED GROUND DOWN.
- 2. WHEN USING A 1/2" RAISED INDUSTRIAL COVER, THE RECEPTACLE SHALL BE MOUNTED TO THE COVER VIA THE MOUNTING HOLES IN THE EARS OF THE RECEPTACLE AND THE CENTER SCREW
- 3. PER CPS SPECIFICATIONS, ALL WIRE WILL HAVE THHN INSULATION.
- 4. WIRE GAUGE /SIZE WILL BE DETERMINED BY THE CITY OF CHICAGO CODE.

CHICAGO PUBLIC SCHOOLS
CAPITAL IMPROVEMENT PROGRAM
INFORMATION TECHNOLOGY SERVICES
INFRASTRUCTURE STANDARDS
TYPICAL 20A ISOLATED GROUND
RECEPTACLES

ı					1000				SHEET NO.
ı					r CPS	Į.			
ı						1			1
ı					CPS				ED.911
ı					00000	PROJECT NUMBER	SCALE	DATE	ED.911
ı					CPS				1
ı		ĺ			A-MONES		NONE	04/10/06	1
	HO.	DATE	FECHION .	87	(PS				
_									